

Fire Sprinkler Systems Annual Test and Inspection Requirements

Fire Sprinkler Systems must be maintained and tested regularly. A quality maintenance program will increase the likelihood that the system will operate as it is designed to do in the event of a fire.

The Eagle River Fire District requires fire sprinkler systems to undergo an annual test and inspection in accordance with NFPA 25. Upon completion of the inspection process and all repairs, the appropriate documentation must be completed and copies forwarded to the property owner, property management, and the Eagle River Fire Protection District - Fire Prevention Bureau.

Should discrepancies or conditions be found that prevent the system from operating as designed, repairs must be scheduled and completed in a timely manner. Major repairs or situations that require that the system be taken out of service for any reason must be reported to the Fire Marshal for review and approval prior to conducting the work.

All Annual Test and Inspections must be recorded and submitted to the Fire District on the most current **National Fire Sprinkler Agency (NFSA)** Inspection and Testing form. Other forms will not be accepted. If such forms are submitted they will be returned and the property in question will be recorded as not in compliance with code until such time the proper documentation is submitted.